

NOTICE FOR ALL SERVICES

URD REQUIREMENTS:

You must give cooperative advance notice of 7 working days before digging the trench.

- Member responsible for opening and closing trench
- Primary trenches must be **42"** minimum depth
- If padmount transformer is needed, member to dig 6' x 6' x 2' deep hole
- Secondary trenches must be **30"** minimum depth
- Install meter base on building or home at correct height (48" – 72")
- Install ground wire inside 1/2" conduit to 5/8" x 8' ground rod with approved clamp

If the trench does not meet the above stated requirements upon arrival of the crew, the service will not be installed. Therefore, work by Cooperative will not be performed until the trench does meet these requirements.

OVERHEAD REQUIREMENTS:

- Install meter base on building or home at correct height (48" – 72")
- Install ground wire inside 1/2" conduit to 5/8" x 8' ground rod with approved clamp
- Install wiring from bottom lugs of meter base to customer breaker panel

Cooperative service wire is always connected to top lugs of meter base or weatherhead.

If breaker panel on building or home is more than 6' from the meter base, an external weather- proof disconnect must be installed.

Meter base must be inspected in required counties. (Spencer and Warrick) Improvement Location Permit required in Perry County.

There will be a **\$300.00** return trip charge for all jobs scheduled by the consumer or contractor failing to meet the above requirements. The \$300.00 fee will be waived if the consumer or contractor cancels the job by 4:00 PM on the previous day by calling 800-323-2316.

I hereby agree to the above conditions and will follow the conditions set forth by Southern Indiana Power.

Consumer Signature: _____

Date: _____

Contractor Signature: _____